

Amendments to the 2015 International Plumbing Code

- **101.1 Title.** (Insert the following)
These regulations shall be known as the International Plumbing Code of the City of Englewood, hereinafter referred to as “this code.”
- **106.6.2 Fee Schedule.** (Add the following)
Refer to Section 109.2 of the amended International Building Code of the City of Englewood for requirements of this section.
- **106.6.3 Fee Refunds.** (Delete in its entirety and substitute the following)
Refer to Section 109.6 of the amended International Building Code of the City of Englewood for requirements of this section.
- **107.4.3 Reinspections.** (Delete in its entirety and substitute the following)
Refer to Section 110.7 of the amended International Building Code of the City of Englewood for requirements of this section.
- **108.4 Violation Penalties.** (Delete in its entirety and substitute the following)
Refer to Englewood Municipal Code 8-1-10 for requirements of this section.
- **108.5 Stop Work Orders.** (Change the last sentence)
Upon notice from the code official that work is being done contrary to the provisions of this code or in a dangerous or unsafe manner, such work shall immediately cease. Such notice shall be in writing and shall be given to the owner of the property, the owner’s agent, or the person doing the work. The notice shall state the conditions under which work is authorized to resume. Where an emergency exists, the code official shall not be required to give a written notice prior to stopping the work. Any person who shall continue any work on the system after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be liable for a fine of not less than [AMOUNT] dollars or more than [AMOUNT] dollars ~~penalties~~ as prescribed in 108.4 as amended.
- **109 MEANS OF APPEAL.** (Delete section in its entirety and substitute the following)
Refer to Title 8-1-7 of the Englewood Municipal Code of the City of Englewood for requirements of this section.
- **305.4.1 Sewer Depth** (Insert the following)
Building sewers that connect to private sewage disposal systems shall be a minimum of 12 inches below finished grade at a point of septic tank connection. Building sewers shall be a minimum of 12 inches below grade.
- **903.1 Roof Extension** (Insert the following)
Open vent pipes that extend through a roof shall be terminated at least 6 inches above the roof, except where a roof is to be used for any purpose other than weather protection, the vent extensions shall be run at least 7 feet above the roof.