

Amendments to the 2015 International Mechanical Code

- **101.1 Title.** (Insert the following)
These regulations shall be known as the Mechanical Code of the City of Englewood, hereinafter referred to as “this code.”
- **106.5.2 Permit Fee Schedule.** (Add the following)
Refer to Section 109.2 of the amended Building Code of the City of Englewood for requirements of this section.
- **106.5.3 Fee Refunds.** (Delete in its entirety and substitute the following)
Refer to Section 109.6 of the amended Building Code of the City of Englewood for requirements of this section.
- **107.3.3 Reinspections.** (Delete in its entirety and substitute the following)
Refer to Section 110.7 of the amended Building Code of the City of Englewood for requirements of this section.
- **108.4 Violation Penalties.** (Delete in its entirety and substitute the following)
Refer to Englewood Municipal Code 8-1-10 for requirements of this section.
- **108.5 Stop Work Orders.** (Change the last sentence)
Upon notice from the code official that work is being done contrary to the provisions of this code or in a dangerous or unsafe manner, such work shall immediately cease. Such notice shall be in writing and shall be given to the owner of the property, the owner’s agent, or the person doing the work. The notice shall state the conditions under which work is authorized to resume. Where an emergency exists, the code official shall not be required to give a written notice prior to stopping the work. Any person who shall continue any work on the system after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be liable for a fine of not less than [AMOUNT] dollars or more than [AMOUNT] dollars ~~penalties~~ as prescribed in 108.4 as amended.
- **109 MEANS OF APPEAL.** (Delete section in its entirety and substitute the following)
Refer to Title 8-1-7 of the Englewood Municipal Code of the City of Englewood for requirements of this section.
- **304.11 Guards.** (Delete in its entirety and substitute the following)
Guards shall be provided where appliances, equipment, fans or other components that require service and roof hatch openings are located within 10 feet (3048 mm) of a roof edge or open side of a walking surface and such edge or open side is located more than 30 inches (762 mm) above the floor, roof or grade below. The guard shall extend not less than 30 inches (762mm) beyond each end of such appliances, equipment, fans, components and roof hatch openings and the top of the guard shall be located not less than 42 inches (1067 mm) above the elevated surface adjacent to the guard. The guard shall be constructed so as to prevent the passage of a 21-inch diameter (533 mm) sphere

and shall comply with the loading requirements for guards specified in the International Building Code.